


American Concrete Institute®  
Advancing concrete knowledge

## The Art of Thermal Mass Modeling for Energy Conservation in Buildings, Part 2


ACI Spring 2012 Convention  
March 18 – 21, Dallas, TX

ACI WEB SESSIONS



**W. Mark McGinley, PhD PE, FASTM** is Professor and Endowed Chair for Infrastructure Research, Civil and Environmental Engineering, J.B. Speed School of Engineering University of Louisville. Dr. McGinley is a structural engineer and building scientist with an excess of 23 years of research and forensic engineering practice in building systems. Prior to joining U of L, he served 20 years at North Carolina A & T State University in the Civil, Architectural, Agricultural and Environmental Engineering Department. He is an expert in masonry building systems, in particular, masonry building envelopes. Dr. McGinley's research has included research on the structural performance of masonry walls, water penetration experiments on envelopes and the building envelope performance of brick veneer and steel stud wall systems. He has also been involved in, multidiscipline efforts on the evaluation of the energy systems of existing buildings and demonstration projects evaluating condensing heat exchangers and thermal mass effects of night time ventilation. He has been a primary author of all 6 editions of the Masonry Designers Guide.

ACI WEB SESSIONS




## Cost Effective Energy Efficient School Design

ACI Convention  
March 19, 2012,

W. Mark McGinley, Ph. D., PE  
FASTM

ACI WEB SESSIONS



### Overview


- Recently completed a project investigating cost effective – energy efficient/sustainable school design, including both first cost and life cycle costs for KY.

WE WERE ASKED THE QUESTION

*"If I had a dollar to spend for energy efficiency where should I send it first?"*

ie. *"Best Bang for the Buck"*


ACI WEB SESSIONS



### Acknowledgments

- Most of the work on this project was performed by Kevin Muldoon and Chad Riggs
- Primary funding was provided by the Kentucky Renewable Energy Consortium

ACI WEB SESSIONS



### Overview

- Study focused on conventional systems with input from design/school community
- Used the range of climates in Kentucky – Climate Zone 4
- Develop relationships between costs and energy efficiencies to allow optimization of both- Holistic approach used.

ACI WEB SESSIONS

### Designed a Base Prototype Middle School –

- Base: Design met Min ASHRAE 90.1
- Most Lights T-12-2 and 4 lamp systems
- HVAC VAV – Gas boilers and Chillers
- Typical school use schedules.
- Minimum Envelope U and R values ~ R 22
- Roof – R-8 @ Walls
- Base EUI - ~132

Base –(www.schoolclearing house.org) -158,000 ft<sup>2</sup> Second-Story-Prototype

ACI WEB SESSIONS

### Analyzed School Building

Analyzed prototype configuration to establish base performance using eQuest (DOE2).

5 KY cities – Corbin, Covington, Louisville, Lexington, Paducah

ACI WEB SESSIONS

### Analysis Results Collated – Base line–

Run status	Energy Efficiency Measure	Construction Data	multiplier	Corbin	Covington	Lexington	Paducah	Louisville
CM #	description	Changes		kWh	kWh	kWh	kWh	kWh
Baseline	Exterior walls R-9.09, layers: outside air film, 4" brick, air space, 1/4" polystyrene 8" CMU MW hollow, air film; Pitched Roof R-22.22, layers: outside air film, steel siding, 8/8 paper felt, 3" polyiso, steel siding, inside air film Built up Roof R-26.3, layers: outside air film, 3" polyiso, 5/8" plywood, metal decking Ceiling R-1.95, layers: 1/2" Acoustic tile; interior wall R-3.75, layers: inside air film, 8" CMU MW		1	2,324,765	2,105,104	2,186,284	2,251,915	2,332,373
Baseline	Baseline Ewall: 9.09 BU/Roof: 26.3 Siding Roof: 22.22 Ceiling: 1.95 Iwall: 3.08			5,630	5,372	5,360	5,622	5,688
Baseline	Exterior walls R-9.80, layers: outside air film, 4" brick, air space, 1/4" polystyrene 8" CMU MW hollow, air film; Roof R-22.72, layers: outside air film, steel siding, 8/8 paper felt, 3" polyiso, steel siding, inside air film Ceiling R-1.95, layers: 1/2" Acoustic tile; Interior walls R-3.75, layers: inside air film, 8" CMU MW hollow, inside air film; Interior floor R-1.94, layers: inside air film, 6" HW Conc., stone 1" Ground floor R-2.59, layers: inside air film, linoleum, 6" HW conc., inside air film Afloor R-16.67, layers: Afr Cons Mat 1, Acoustic tile			11,080,212	12,327,790	12,216,	11,645,294	12,435,
Baseline	Baseline Ewall: 9.08 BU/Roof: 22.72 Siding Roof: 22.22 Ceiling: 1.95 Iwall: 3.08 Ground Floor: Afloor:						132	2,253,991
Baseline							5,622	11,610,529
Baseline							132	11,610,529
Baseline							5,622	11,610,529
Baseline							132	11,610,529

ACI WEB SESSIONS

### Investigated Energy Conservation Measures

Based on input from

- design community
- facility managers
- Contractors
- literature, etc.

Mature alternative energy conservation measures ECM's (technologies) were identified and incorporated into the building.

Prototype building re-analyzed eQuest (DOE2) for Each ECM singly and in groups - 5 KY cities

ACI WEB SESSIONS

### Evaluated Select Alternatives (ECM's):

- T8 lights – HO instead of Halides in High bay areas
- More efficient Conventional HVAC systems - Boiler
- Day-lighting controls
- Setback - Fan controls
- ERV's
- VFD Motors
- Ground Source and Water Source Heat Pumps
- Enhanced building envelopes – Both light framed and mass walls, high and low U windows, High R roofs
- tighter envelopes
- Occupancy sensors and schedules based on occupancy- etc.

ACI WEB SESSIONS

CM #	description	Changes	Demand	Corbin	Covington	Lexington	Paducah	Louisville
CM #	description	Changes		kWh	kWh	kWh	kWh	kWh
C-1	Pitched Roof R-25.94 Built up Roof R-29.41	Change 3" exterior Polystyrene to 1.5" exterior Polystyrene	Electric Gas	5,628 11,057,305	5,275 12,281,564	5,275 12,281,564	5,275 12,281,564	5,275 12,281,564
C-2	Pitched Roof R-29.41 Built up Roof R-33.33	Change 3" exterior Polystyrene to 4" exterior Polystyrene	Electric Gas	5,627 11,039,218	5,269 12,242,300	5,269 12,242,300	5,269 12,242,300	5,269 11,842,843
C-3	Pitched Roof R-37.34 Built up Roof R-40.00	Change 3" exterior Polystyrene to 5" exterior Polystyrene	Electric Gas	5,625 11,011,239	5,267 12,196,233	5,267 12,196,233	5,267 12,196,233	5,267 11,800,659
C-4	ICF walls R-21.74	ICF Wall: air film, 4" brick, air space, 1.5" Polyethylene, 4" 800 gsm, 1.5" Polyethylene, 1/2" gypsum board, air film	Electric Gas	5,631 11,045,693	5,272 12,151,629	5,272 12,052,700	5,272 11,946,113	5,272 11,799,442
C-5	CMU walls R-25	Changed 1.5" Polystyrene to 3" polyiso	Electric Gas	5,629 11,045,519	5,271 12,133,630	5,271 12,036,615	5,271 11,930,588	5,271 11,795,807
C-6	CMU walls R-18.18	Changed 1.5" Polystyrene to 2" polyiso	Electric Gas	5,629 11,050,652	5,271 12,177,489	5,271 12,080,000	5,271 11,974,081	5,271 11,815,560
C-7	CMU walls R-13.33	Changed 1.5" Polystyrene to 1.5" polystyrene	Electric Gas	5,629 11,065,140	5,271 12,231,706	5,271 12,134,544	5,271 11,908,988	5,271 11,805,189
C-8	Steel Stud Walls R-34.5	Steel stud wall layers: air film, 4" face brick, air space, 3.5" polyiso, 2nd wall 80.0 C-8-19 batt insul, gypsum board air film	Electric Gas	5,631 11,040,827	5,272 12,117,113	5,272 12,018,283	5,272 11,829,302	5,272 11,781,746

Run eQuest on each in Building Config. – 5 Ky

2,253,728
5,623
11,546,113
131 / 5%
2,253,297
5,621
11,536,908
131 / 6%

ACI WEB SESSIONS

Item#	Energy Efficiency Measure	Construction Data	Multiplier	LCR/Wh/Wh/Wh/Wh	Wh	Wh	Wh	Wh	Wh	Wh
CM#	Description	Changes	1	1	kWh	kWh	kWh	kWh	kWh	kWh
					<b>2,136,992</b>					
L1	T8 Lighting	Change all building lights from T12 to T8, Change ballast from Energy Efficient Magnetic to Rapid Start Electronic	Electric	2,207,589	2,088,496	2,089,607	2,136,992	2,195,376	5,116	4,855
			Demand	5,629	5,271	5,368	5,622	5,688	5,175	5,175
			L 1 EU	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%
L2	Modified Lighting Schedule	Occupancy Sensors	Electric	2,231,810	2,062,348	2,091,461	2,161,117	2,219,889	5,629	5,271
			Demand	5,629	5,271	5,368	5,622	5,688	5,175	5,175
			L 2 EU	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%
L.1	T8 Lighting	Change all building lights from T12 to T8, Change ballast from Energy Efficient Magnetic to Rapid Start Electronic	Electric	2,207,589	2,088,496	2,089,607	2,136,992	2,195,376	5,116	4,855
			Demand	5,629	5,271	5,368	5,622	5,688	5,175	5,175
			L 1 EU	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%
M3	Daylighting	Using light sensors to change lighting levels	Electric	2,317,886	2,147,723	2,176,771	2,246,527	2,305,457	5,629	5,271
			Demand	5,629	5,271	5,368	5,622	5,688	5,175	5,175
			M 3 EU	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%
M4	Water Side Economizer	Install heat exchanger that uses free cooling	Electric	2,622,678	2,445,120	2,476,611	2,500,008	2,622,113	5,629	5,271
			Demand	5,629	5,271	5,368	5,622	5,688	5,175	5,175
			M 4 EU	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%
M5	Minimum OA Schedule	Closes OA Damper during unoccupied periods unless when calling for economizer mode	Electric	2,260,468	2,114,538	2,143,042	2,198,054	2,259,093	5,629	5,271
			Demand	5,629	5,271	5,368	5,622	5,688	5,175	5,175
			M 5 EU	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%
M6	Modified Fan Schedule	HVAC Systems shut down during the period of 7PM and 6 AM. If any zone falls below heating setpoint the unit will cycle on for 1 hour.	Electric	1,913,418	1,795,622	1,814,150	1,883,953	1,912,816	5,629	5,271
			Demand	5,629	5,271	5,368	5,622	5,688	5,175	5,175
			M 6 EU	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%
					<b>Electric 2,253,991</b>					
					<b>Demand 5,622</b>					
					<b>Gas 11,645,294</b>					
					<b>EUI 132</b>					

Item#	Energy Efficiency Measure	Construction Data	Multiplier	LCR/Wh/Wh/Wh/Wh	Wh	Wh	Wh	Wh	Wh	Wh
CM#	Description	Changes	1	1	kWh	kWh	kWh	kWh	kWh	kWh
					<b>2,136,992</b>					
L1	T8 Lighting	Change all building lights from T12 to T8, Change ballast from Energy Efficient Magnetic to Rapid Start Electronic	Electric	2,207,589	2,088,496	2,089,607	2,136,992	2,195,376	5,116	4,855
			Demand	5,629	5,271	5,368	5,622	5,688	5,175	5,175
			L 1 EU	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%
L2	Modified Lighting Schedule	Occupancy Sensors	Electric	2,231,810	2,062,348	2,091,461	2,161,117	2,219,889	5,629	5,271
			Demand	5,629	5,271	5,368	5,622	5,688	5,175	5,175
			L 2 EU	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%
M1	90% Boiler Efficiency	Cooling Unoccupied - 90°F Heating Unoccupied - 55°F	Electric	2,151,275	2,241,089	2,300,129	2,300,129	2,300,129	5,629	5,271
			Demand	5,629	5,271	5,368	5,622	5,688	5,175	5,175
			M 1 EU	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%
M2	Large Temperature Setback	Cooling Unoccupied - 90°F Heating Unoccupied - 55°F	Electric	2,151,275	2,241,089	2,300,129	2,300,129	2,300,129	5,629	5,271
			Demand	5,629	5,271	5,368	5,622	5,688	5,175	5,175
			M 2 EU	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%
L.2	Modified Lighting Schedule	Occupancy Sensors	Electric	2,231,810	2,062,348	2,091,461	2,161,117	2,219,889	5,629	5,271
			Demand	5,629	5,271	5,368	5,622	5,688	5,175	5,175
			L 2 EU	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%
M5	Minimum OA Schedule	Closes OA Damper during unoccupied periods unless when calling for economizer mode	Electric	2,260,468	2,114,538	2,143,042	2,198,054	2,259,093	5,629	5,271
			Demand	5,629	5,271	5,368	5,622	5,688	5,175	5,175
			M 5 EU	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%
M6	Modified Fan Schedule	HVAC Systems shut down during the period of 7PM and 6 AM. If any zone falls below heating setpoint the unit will cycle on for 1 hour.	Electric	1,913,418	1,795,622	1,814,150	1,883,953	1,912,816	5,629	5,271
			Demand	5,629	5,271	5,368	5,622	5,688	5,175	5,175
			M 6 EU	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%
					<b>Electric 2,253,991</b>					
					<b>Demand 5,622</b>					
					<b>Gas 11,645,294</b>					
					<b>EUI 132</b>					

Item#	Energy Efficiency Measure	Construction Data	Multiplier	LCR/Wh/Wh/Wh/Wh	Wh	Wh	Wh	Wh	Wh	Wh
CM#	Description	Changes	1	1	kWh	kWh	kWh	kWh	kWh	kWh
					<b>2,136,992</b>					
L1	T8 Lighting	Change all building lights from T12 to T8, Change ballast from Energy Efficient Magnetic to Rapid Start Electronic	Electric	2,207,589	2,088,496	2,089,607	2,136,992	2,195,376	5,116	4,855
			Demand	5,629	5,271	5,368	5,622	5,688	5,175	5,175
			L 1 EU	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%
L2	Modified Lighting Schedule	Occupancy Sensors	Electric	2,231,810	2,062,348	2,091,461	2,161,117	2,219,889	5,629	5,271
			Demand	5,629	5,271	5,368	5,622	5,688	5,175	5,175
			L 2 EU	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%
M1	90% Boiler Efficiency	Cooling Unoccupied - 90°F Heating Unoccupied - 55°F	Electric	2,151,275	2,241,089	2,300,129	2,300,129	2,300,129	5,629	5,271
			Demand	5,629	5,271	5,368	5,622	5,688	5,175	5,175
			M 1 EU	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%
M6	Modified Fan Schedule	HVAC Systems shut down during the period of 7PM and 6 AM. If any zone falls below heating setpoint the unit will cycle on for 1 hour.	Electric	1,913,418	1,795,622	1,814,150	1,883,953	1,912,816	5,629	5,271
			Demand	5,629	5,271	5,368	5,622	5,688	5,175	5,175
			M 6 EU	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%	132 / -1%
					<b>Electric 2,253,991</b>					
					<b>Demand 5,622</b>					
					<b>Gas 11,645,294</b>					
					<b>EUI 132</b>					

### Select Findings on Energy Savings:

- T8 reduces elect. energy ↓6% but heating ↑3% - EUI almost unchanged –Energy Cost savings ~3%.
- Envelope improvements have generally less than 1% change in EUI.
- Increased boiler efficiency to 90% can save about 9%.
- ERV systems can actually increase overall energy used in certain conditions.

### Select Findings on Energy Savings:

- Controls have significant effects- 19- 25%
  - Set backs.
  - Modified fan schedule (periodic ventilation).
  - VAV- minimum air flow reduction (close – unoccupied)
- Can get near ↓ 56% EUI -using conventional systems
- Geothermal ↓ 80% EUI

### Controls

- Simple controls can have significant effects
  - Base set backs 64°F and 80°F reduces EUI ~30+%
  - Set-backs 55°F & 90°F reduces EUI another 19%
  - Can use programmable thermostats or DDC of all thermostats – be careful of IAC and Mold

### Controls

VAV- minimum air flow ~ ↓ 25% reduction in EUI

Allows the damper controlling the minimum air flow in a VAV box to fully close during unoccupied periods if the room temperature is satisfied.

May need modification of VAV boxes in conventional construction– occupancy sensors – DDC system.

ACI WEB SESSIONS

### Controls

Modified fan schedule (periodic ventilation) ~↓21% EUI

The air handler units are shut down during the unoccupied periods (7 pm – 6 pm). If any zone falls below the heating set point the unit will cycle on for 1 hour.

For periodic ventilation outside of occupancy periods- energy management/control system of some sort is needed (DDC)

ACI WEB SESSIONS

### EUI % Reduction

ECM	Corbi	Connet	Lexing	Louisv	Paduc
C.3	0.4%	0.8%	0.7%	0.6%	0.8%
C.14	0.2%	1.0%	1.2%	0.9%	0.8%
C.14	0.6%	0.9%	0.8%	0.7%	0.8%
M.2	19.6%	19.3%	19.0%	18.7%	19.0%
M.6	23.4%	19.7%	20.3%	21.1%	20.3%
M.10	41.7%	35.1%	35.7%	37.3%	36.1%
VAV ALL	61.0%	57.6%	58.1%	58.5%	58.5%
G.M.17	72.6%	71.6%	72.1%	72.9%	73.6%
G.M.20	77.2%	75.9%	76.3%	76.2%	75.9%
G.Options	79.9%	79.7%	80.1%	79.7%	79.5%

C.3	Change 3" exterior Polysocyanurate to 5" exterior Polysocyanurate (Roof)
C.14	Air barrier – 0.2 Air changes per hour
C.5	Change 1-1/4" Polystyrene to 3" polysocyanurate (CMU Walls)
M.2	Large Temperature Setbacks
M.6	Modified Fan Schedule – Fans to shut down during unoccupied hours until a space drops below the setpoint temperature
M.10	VAV Box Minimum Air Flow Schedule – Dampers on the VAV boxes to close if the space temperature setpoint is satisfied.
VAV ALL	Best ECMs for the baseline building modeled as one ECM. Most efficient building design for the VAV system.
G.M.17	Replace the VAV HVAC System with a Geothermal Heat Pump System
G.M.20	Modified Fan Schedule – Fans to shut down during unoccupied hours until a space drops below the setpoint temperature
G.Options	Best ECMs for the baseline building modeled as one ECM. Most efficient building design for the geothermal system.

ACI WEB SESSIONS

### Economic Analysis:

- Determined the cost of the electricity and gas using the LG&E/KU commercial utility rate structure for each analysis
- Estimated cost of Building \$17,540,000 – about \$111/ft<sup>2</sup>
- Conducted quantity takeoff on systems that were changed and developed incremental change in capital costs using input from RsMeans – Cert. Construct. Estimator, input from contractors and Energy Enrgs. – For each ECM

ACI WEB SESSIONS

### Economic Analysis:


A. Determined simple payback for each ECM – Capital cost increase / yearly energy savings.

B. Using 4.5 % interest rate and 1.5% estimated increase in energy determined year self funding – for longer periods – 50 to 75 year design lives – included estimated maintenance costs where different from base conditions.

ACI WEB SESSIONS


ECM	Description	Cost	Savings	SPB (Years)	5F in Year
A.45	Varying the Orientation - No Cost	\$ -	\$ 98.72	0.0	NO COST ECM
A.90	Varying the Orientation - No Cost	\$ -	\$ 5.69	0.0	NO COST ECM
A.135	Varying the Orientation - No Cost	\$ -	\$ 44.71	0.0	NO COST ECM
A.180	Varying the Orientation - No Cost	\$ -	\$ (107.78)	0.0	NO IMPROVEMENT
A.225	Varying the Orientation - No Cost	\$ -	\$ (152.89)	0.0	NO IMPROVEMENT
A.270	Varying the Orientation - No Cost	\$ -	\$ (156.24)	0.0	NO IMPROVEMENT
A.315	Varying the Orientation - No Cost	\$ -	\$ 26.39	0.0	NO COST ECM
C.1	Change 3" exterior Polysocyanurate to 3.5" exterior	\$ 84,274.71	\$ 330.02	255.4	-
C.2	Change 3" exterior Polysocyanurate to 5" exterior	\$ 94,678.99	\$ 592.28	159.9	-
C.3	Change 3" exterior Polysocyanurate to 4" exterior	\$ 187,277.13	\$ 993.39	188.5	-
C.4	ICF Wall: air film, 4" brick, air space, 1.5" Polyurethane, 6"	\$ 252,986.52	\$ 755.20	335.0	-
C.5	Changed 1-1/4" Polystyrene to 3" polyiso	\$ 66,693.99	\$ 877.44	76.3	-
C.6	Changed 1-1/4" Polystyrene to 2" polyiso	\$ 8,923.19	\$ 686.98	13.0	17
C.7	Changed 1-1/4" Polystyrene to 1-1/2" polyurethane	\$ -	\$ 438.10	0.0	NO COST ECM
C.8	Steel wall stud layers air film, 4" face brick, air space, 3.5" polyiso, 2x6 steel wall 16 O.C. R-19 batt insul, gypsum board air film	\$ (255,556.89)	\$ 868.51	-294.2	NO COST ECM
C.9	Steel wall stud layers: air film, 4" face brick, air space, 2" polyiso, 2x6 steel wall 16 O.C. R-19 batt insul, gypsum board air film	\$ (309,542.18)	\$ 739.09	-418.8	NO COST ECM
C.10	Steel wall stud layers: air film, 4" face brick, air space, 1.5" Polystyrene, 2x6 steel wall 16 O.C. R-19 batt insul, 1/2" GYP board, air film	\$ (326,942.39)	\$ 495.87	-659.3	NO COST ECM
C.11	Steel wall stud layers: air film, 4" face brick, air space, 3" Polystyrene, 2x6 steel wall 16 O.C. No batt insul, 1/2" GYP board, air film	\$ (313,557.63)	\$ 500.51	-626.5	NO COST ECM
C.12	Light Vapor Barrier	\$ -	\$ (180.49)	0.0	NO IMPROVEMENT
C.13	Medium Vapor Barrier	\$ 42,385.14	\$ 725.60	58.4	-
C.14	Heavy Vapor Barrier	\$ 84,770.28	\$ 1,573.12	53.9	-
A.15	Wall: air film, 4" brick, air space, 1.5" Polyurethane, 6" 140lb conc., 1.5" Polyurethane, 1/2" gyp board, air film; for roof: changed 3" exterior Polysocyanurate to 5" exterior Polysocyanurate	\$ 440,263.65	\$ 1,553.44	283.4	-

ACI WEB SESSIONS





ECM	Description	Cost	Savings	SPB (Years)	SF In Year
M.1	Condensing Boiler	\$ 2,264.60	\$ 9,492.31	0.2	
M.2	Large Temperature Setbacks	\$ -	\$ 27,813.53	0.0	NO COST ECM
M.3	Daylighting	\$ 17,113.27	\$ 1,021.24	16.8	24
M.4	Water Side Economizer	\$ -	\$ (27,538.22)	0.0	NO IMPROVEMENT
M.5	Minimum OA Schedule	\$ 169,990.00	\$ 4,605.77	36.9	
M.6	Modified Fan Schedule	\$ 169,990.00	\$ 48,868.29	3.5	4
M.7	VFD on Cooling Tower Fan	\$ 11,869.00	\$ 7,123.72	1.7	2
M.8	3-Way to 2-Way Valves and VFD on Pumps	\$ 15,886.20	\$ 28,698.77	0.6	1
M.9	ERV on AHUs	\$ -	\$ (43,919.85)	0.0	NO IMPROVEMENT
M.10	VAV Box Minimum Air Flow Schedule	\$ 169,990.00	\$ 74,569.17	2.3	3


- Note the lighting ECM's saves some electrical energy but increase heating energy in winter
- More efficient lights and occupancy sensors on lights have lower payback periods for new schools, although aggressive sensor driven daylighting may take a while.



### We looked at typical Kentucky performance:

- We then asked the question - How will the school perform in other climates?
- Ran the base school and critical ECM's in Dallas, Miami, and Madison.
- The following results were obtained





### Conclusions

- Over 50% can be saved in typical school configurations using conventional HVAC systems and aggressive control strategies. These improvements generally have aggregate paybacks of less than 3 years.
- Use of ground source heat pumps greatly increase the energy saved but have much higher payback periods, usually in excess of 20 years.

### Conclusions

- Envelope improvements in typical school configurations have a minimal impact on energy used in most Kentucky climates and generally have long payback periods (in excess of 100 years)
- Many of the findings of this investigation can be applied to school retrofits – controls – set backs occupancy controlled ventilation, fans , lights.
- Most of these findings appear applicable to most climates.

# THANK YOU !

# QUESTIONS?